

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. १२७/महाराष्ट्र नगरपालिका/२०२३-२४

Dated: 30/06/2023

It is certified that an inspection team headed by Sh. Chandra Pal Singh, A.C.
(Name of Officers with designation) from Nagar Palika Parishad, Marehra
(Name of Department/ Office) inspected the Angel The Future School, Marehra
(Name & Address of the school) on 30-06-23 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of two years

Signature with Seal: [Signature] 30/06/23

Name अधिसासी अधिकारी
महाराष्ट्र नगरपालिका परिषद, महारा

Designation : जनप्रद-एच

Assistant Engineer of
the Govt. Public Health Department (PHED)//
Authorised officer of the Local Body

Name & Address of the Office / Department :

To

Angel The Future School

Mirehchi Road, Marehra (Etah) - 207401

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

[Signature]
Manager
Angel The Future School
Mirehchi Road, Marehra
Etah-207401

[Signature]
Principal
Angel The Future School
Marehra (Etah)-207401



Office of Executive Engineer, Jal Nigam
(Gramin) Etah U.P.
Analysis Report of Water

To,

Report No.259

Place/Source of Samplin-S. Sevel Angel The Future School Marehra (Etah)

Village Name- Marehra Block-Marehra District- Etah

Name of Sample Collector- - Ram Babu Date/Time- 12-06-2023 12:20 pm


Date of Analysis- 13-06-2023

Latitude-

Longitude-

S. No.	Parameter (Unit)	BIS Acceptable Limit	Unit Mg/l	BIS Permissible Limit in Absence of alternate source	Result	Remarks
1	Turbidity	1.0	NTU	5	1.88	
2	pH	6.5-8.5	-	No Relaxation	7.02	
3	Chloride	250	Mg/l	1000	64	
4	TDS	500	Mg/l	2000	318	
5	Alkalinity	200	Mg/l	600	48	
6	Fluoride	1	Mg/l	1.5	0.5	
7	Nitrate	45	Mg/l	No Relaxation	1.22	
8	Sulphate	200	Mg/l	400	38	
9	Total Hardness	200	Mg/l	600	88	
10	Iron	1	Mg/l	No Relaxation	0.1	
11	Total Arsenic	0.01	Mg/l	No Relaxation	0.0	
12	Calcium	75-200	Mg/l		48	
13	Magnesium	30-100	Mg/l		40	
14	Colour	5-15	Hazen Unit		5	
15	Odour	-	-		Odourless	
16	Taste	-	-		Sweet	
17	Total Coliform			Shall not be Detectable in any 100 ml Sample	Not Detected	
18	E.coli			Shall not be Detectable in any 100 ml Sample	Not Detected	


Manager
Angel The Future School
Marehchi Road, Marehra
Etah-207401


Principal
Angel The Future School
Marehra (Etah)-207401


Authorized Signatory
U.P. Jal Nigam (Etah)